

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

**M/s National Hospital
Karan Bagh, Airport Road
Jammu**

No: DFES-FP/2/2022-04 (CC-7079330) **290**

Dated: **30.01.2026**

Sub: Renewal of Fire Safety Measures/Guidelines in favour of National Hospital ---Annual Clearance thereof.

Ref: Your online submission application dated: 16.01.2026 (FI026-01540317).

The spot inspection of above said hospital has been got carried out by the inspecting officer of this department. During inspection, it was found that the management has installed Sprinklers (in basement only), Fire Hydrants, Hose Reel Hoses, Smoke Detectors/Alarm system and First Aid Fire Extinguishers in their hospital premises, besides this, one underground water storage tank of 50 KL capacity is also available. Moreover, the site is about 09 Km away from Fire & Emergency Station Gandhi Nagar and is approachable for fire appliances in case of any emergency. Since the hospital is already functioning. As such, the management can proceed ahead for operation subject to strictly adopt the following fire safety measures/ guidelines for effective and betterment of the hospital:-

FIRE SAFETY PRECAUTIONARY MEASURES / GUIDELINES FOR IMPLEMENTATION:-

1. At least four dedicated persons working in your hospital be earmarked as Fireman who can maintain firefighting system and its operation in case of emergency round the clock. However, on your personal request, any assistance in terms of training of your employees if required for handling/operating the fixed/first aid firefighting equipment installed in your hospital. The nearest fire & emergency station can be approached for the same.
2. Emergency Evacuation Drills shall be prepared by the concerned authority since patients of different categories are involved during evacuation in case of earthquake or in any emergency as the firemen are not well trained in handling the ambulatory persons/patients. The employees of Health Department i.e. Doctors, Para Medical Staff, Nurses & Nursing Orderlies etc. should be trained and responsible for evacuation of patients in any emergency like fire, earthquake etc.
3. Automatic Sprinkler System should be installed in the entire hospital premises strictly as per NBC Part - IV (i.e. Fire & Life Safety Norms). Moreover, the Fixed Firefighting System already installed shall be on automatic pressurized mode 24x7 for its instant use in case of any fire.
4. Fire Pumps feeding Fire Hydrant/Sprinkler Line should be installed strictly as per NBC Part-IV (Fire & Life Safety Norms).
5. All exit/staircase existing in the building should always free from any obstruction for quick and safe evacuation of inmates in case of any emergency.
6. No Hazardous material should be kept inside the Hospital premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance issued shall be treated automatically withdrawn / cancelled.
7. At present Hospital is having two Blocks, one is four storied with basement and another is triple storied with Basement. As such no addition/alteration should be made by the management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance issued shall be treated automatically withdrawn/cancelled.
8. The department can make a surprise visit to your hospital at any time. During the visit, if the firefighting system already installed in the Hospital premises found defunct and deviation, this clearance issue shall be treated automatically withdrawn/ cancelled.
9. **This clearance shall be subject to outcome of any dispute/investigation/enquiry/ trial if any, pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued. Further, the status with regard to land shall be the responsibility of the concerned registering authority.**
10. **The instant clearance is strictly for adoption of fire safety measures/guidelines of the occupancy only and not for authentication of any other claim.**
11. The validity of this clearance shall remain in force for **one year** from the date of issue of this letter and same needs to be renew after inspection/checking of entire firefighting system (i.e. existing as well as proposed) installed in the hospital by the technical officer of this department.


Director 30/01/2026
Fire & Emergency Services, J&K
 **Jammu/Srinagar**